2N

Integration Manual

Device Category

✓ ACS	IAS	FPS	CCTV	DVR	Perimetry	Building	External	✓ Other

Supported Functionality

Import From File	Combined Credentials
Lift	Encrypted Communication
Device Auto Import	Time Synchronization
Time Zone Support	Live Video Streaming
Recorded Video Streaming	Video Records Downloading
Voice Transmitting	Audio Streaming
PTZ	Presets
Motion Detection	Live Stream Snapshot
Recorded Stream Snapshot	Multiple Stream Types
Fire Panel Networking Mode	✓ Card Learning
Dynamic Upload	✓ Access Time Restriction
✓ Holidays Support	✓ Pin Management
✓ Card Management	Fingerprint Management
Reserved Memory Zones	Antipassback Forgiveness
Handicapped Flag	Alarm Suppression
Fire Alarm Counter	Device Audit Log Retrieval
Remote Device Control	Dynamic Command State
Wiegand Biometric Support	

Legend:

- ✓ Fully supported functionality.
- **O** Partially supported functionality, see results of integrations tests for more details.

Licensed Unit

• 2N

Default Credentials

Кеу	Value
Login	admin
Password	2n

How to Connect Device to C4

The 2N device is connected to the Local Area Network. The intercom is supplied via PoE or an external power supply.

Refer to product support web sites for more 2N configuration details.

The minimal version of the device FW is 2.27

API Access

Make basic configuration after connecting the device to the LAN.Default access values are (Login: admin, Password: 2n). The C4 - 2N communication runs via the intercom HTTP API. Set the API login data and enable the API functions to access this function. Go to the Services menu and select the HTTP API submenu via the 2N web interface. Enable the functions, select the TCP connection type and set the authentication type to None or Basic as shown in the figure below. The HTTPS protocol is not supported.

Services Accou	nt 1 Acco	ount 2 Account 3 Acco	unt 4 Account 5	
HTTP API Ser	vices ~			
SERVICE	ENABLE	CONNECTION TYPE	AUTHENTICATION	
System API	~	Unsecure (TCP) *	Basic •	
Switch API	~	Unsecure (TCP) •	Basic •	
I/O API	~	Unsecure (TCP) •	Basic •	
Audio API	~	Unsecure (TCP) •	Basic •	
Camera API	✓	Unsecure (TCP) •	Basic •	
Display API	✓	Unsecure (TCP) •	Basic •	
E-mail API	✓	Unsecure (TCP) •	Basic •	
Phone/Call API	✓	Unsecure (TCP) •	Basic •	
Logging API	✓	Unsecure (TCP) •	Basic •	

Now switch the tab to Account 1 and enable the account. The HTTP API login data settings are optional and need not be completed. Select User rights in the User Settings as shown in the figure below and save the changes. You can set Authentication as a None or Basic (User and password protected). If some parts of HTTP API is inaccesible, than it will be displayed in Device tree in black color. Example of unsupported Switch API is on following picture.



Settings of User Privileges for Account is also important. If you have only monitoring enabled, then you can see statuses only and sending commands will end with error.

Phone	Account Enabled			
	User Settings ~			
Streaming	550	User Name	admin	
Onvif		Password		
E-Mail	Lines Del Harris			
Automation	User Privileges ~		MONITORING	CONTRO
HTTP API	> System Access			~
User Sounds	Phone/Call Access		~	~
Web Server	I/O Access		~	~
Audio Test	Switch Access			~
SNMP	Camera Access		•	
	UID (Cards & Wiegand) Access			
	Keyboard access		~	

SIP Account Setting

Set the SIP account in the intercom to enable outgoing calls to a defined phone number. Select Telephone in the Services menu. Refer to the figure below for an example of functional setting.

		Intercom Identity ~		
Phone	,	Display Name	2N Helios IP Verso	
Streaming		Phone Number (ID)	520	
Onvif		Domain	10.0.25.74	
E-Mail		Authentication ~		
Automation		Use Authentication ID	~	
HTTP API		Authentication ID	520	
User Sounds		Password		
Web Server		SIP Proxy -		
Audio Test		Proxy Address	10.0.25.74	
SNMP		Proxy Port	5080	
SINNE		SIP Registrar ~		
		Registration Enabled	~	
		Registrar Address	10.0.25.74	
		Registrar Port	5080	

Switch Settings

Set the 2N switch controlling parameters as shown in the figure below.

				2N Helios IP Verso	CZ EN DE F	R IT ES	RU	Logout
۲	Hardware	5	witch 1 Switch 2 Sw	itch 3 Switch 4	Advanced			
	_	~	Switch Enabled					
102	Switches	>	Basic Settings ~					
- - - - - - - - - - - - - - - - - - -	Audio		com occurgo	Switch Mode	Monostable		Ĩ	
<u></u>	Camera		1	witch-On Duration	5		[5]	
2	Keyboard			Time Profile	[not used]	•		
	Buttons		Distin	guish on/off codes				
	Digital Inputs	- 14 - 14 - 14 - 14	Output Settings ~					
- 1	Extenders			Controlled Output	Relay 1	•		
- 1				Output Type	Normal	•		
- 1		- F	Switch Codes ~					
- 1			CODE	ACCESS	JEILITY	TIME PRO	FILE	
- 1		1	00	Key	oad, DTMF 🔹	[not u	sed]	
- 1		2		Keyt	ad, DTMF 🔹	[not us	sed]	•
- 1								
- 1			Extended Activation	•				
- 1			State Signalling >					

How to find PortName for Input and Output

PortName configuration parameters determine physical port on HW. Unfortunately there is no way how to find exact value in classical web interface on 2N device. Use API call /api/io/status in your browser to find value. You can find PortName values right from "port".

Note: Webbrowser can ask for API login credentials to perform api command. API login credentials are stored in device web (Service -> HTTP API ->Account 1 - Account 5)

Switch function on 2N device must be enabled. Refer to product documentation to proper device configuration.

Example in MS Edge browser:

```
192.168.0.104
                       X
                            +
              \bigcirc
\leftarrow \rightarrow
                       192.168.0.104/api/io/status
{
  "success" : true,
  "result" : {
    "ports" : [
      {
         "port" : "led secured",
         "state" : 0
      },
       {
         "port" : "relay1",
         "state" : 0
      },
       1
         "port" : "output1",
         "state" : 1
      },
      {
         "port" : "input1",
         "state" : 0
      },
      {
         "port" : "ext1.relay1",
         "state" : 0
      },
      {
         "port" : "ext1.relay2",
         "state" : 0
      },
      {
```

Door Settings

In order for the door node in C4 to correctly reflect the status of the actual door, it is necessary to set up the 2N device in the following way:

		Door Lock 🗸		
Switches		Assigned Switch	Switch 1	~
Door	>			
Audio		Door Open Sensor ~		
		Assigned Input	Input 1	~
Camera		Input Mode	Non Inverted	~
Buttons		Unauthorized Door Open Detection	✓	
Backlight		Door Open Too Long Detection	✓	
Digital Inputs		Maximum Door Open Time	10	[s]

Namely it is necessary to set the "Door Open Sensor" -> "Assigned Input" to the actual connected input in the 2N device. In this example it is "Input 1". Then the C4 will reflect the door state based on the state of the selected digital input.

Credentials support

- Only two cards for one user are enabled
- Only one PIN for one user is enabled (Pin is stored to User Switch Codes Switch 1)

Configuration

2N

• This is *root device*.

PROPERTY	RANGE	DEFAUL
Location		
Device location		
Persons Management		Enabled
Disable/Enable persons management		
TimeoutMs	0 - 4,294,967,295	10000
General timeout of communication in ms		
Ip	IPv4 address format xxx.xxx.xxx	
IP address of device		
Account		
2N HTTP API access user name		
Password		
2N HTTP API access password		
Enabled	True/False	True
Driver enable/disable		
Door		
• This device can be added under device 2N.		
PROPERTY	RANGE	DEFAULT

DEFAULT

RANGE

• This device can be added under device 2N.

PROPERTY

Phone number

• This device can be added under device *Phone*.

PROPERTY	RANGE	DEFAULI
PhoneNumberForSendCallDial P	honeNumberSelector	
Selection of default phone number for the given SIP account		
PhoneNumber		
Phone number for destination call. (1005, sip:200@192.168.1.1)		
PhoneNumberParallelCallIndicator	true/false	
Indicator whether to include this phone number in the group calling		
PhoneNumber2		
Phone number for destination call. (1005, sip:200@192.168.1.1)		
PhoneNumber2ParallerCallIndicator	true/false	
Indicator whether to include this phone number in the group calling		
PhoneNumber3		
Phone number for destination call. (1005, sip:200@192.168.1.1)		
PhoneNumber3ParallelCallIndicator	true/false	
Indicator whether to include this phone number in the group calling		
DeputyName		
Name of the SIP account to which the call will be routed in case of inaccessible	ility	
ButtonPosition		1
Indicates to what hardware button of the device this SIP account should be a	ssigned	
TimeProfileNumberIn2N_1	1-20	
Number representing Time Profile in 2N device which should be assigned to a 1-based. When empty or equal to zero, the property will not be used and the this phone number.	this phone number. The re will be no time profil	number is e set for
TimeProfileNumberIn2N_2	1-20	
Number representing Time Profile in 2N device which should be assigned to 1-based. When empty or equal to zero, the property will not be used and the this phone number.	this phone number. The re will be no time profil	number is e set for
TimeProfileNumberIn2N_3	1-20	
Number representing Time Profile in 2N device which should be assigned to 1-based. When empty or equal to zero, the property will not be used and the this phone number.	this phone number. The re will be no time profil	number is e set for

• This device can be added under device *Door*.

PROPERTY

Input

• This device can be added under device *Door*.

PROPERTY

PortName Identification of input on 2N device

Output

• This device can be added under device *Door*.

RANGE

RANGE

DEFAULT

DEFAULT

PROPERTY

PortName

Identification of output on 2N device

Switch Output

• This device can be added under device Door.

PROPERTY	RANGE	DEFAULT
SwitchNumber	SwitchNumbers	None
Identification of Switch in 2N device		

Defined Enumerations

PhoneNumberSelector

Used by Phone number > PhoneNumberForSendCallDial.

Value	Description
PhoneNumber	
PhoneNumber2	
PhoneNumber3	

SwitchNumbers

• Used by Switch Output > SwitchNumber.

Value	Description
None	
Switch1	Identification of Switch1
Switch2	Identification of Switch2
Switch3	Identification of Switch3
Switch4	Identification of Switch4

Difference between Switch and output

Main purpose of Switch is providing simple control of door lock via time limited impulse. This impulse can be defined in device settings (web device interface: Hardware - Switches). Main purpose of Output is direct control of relay in device by commands Open and Close.

Limitations of Person Management Systems in this driver

- Only two cards for one user are enabled
- Only one PIN for one user is enabled (Pin is stored to User Switch Codes Switch 1)

Integration Tests

Test	Name	Result
Supported	Functionality > Card Learning	
T09UVU	Personal Management - Card Learning	✓ Passed
Supported 2	Functionality > Access Time Restriction	
T09LQY	Personal Management - Access Time Restriction	✓ Passed
Supported	Functionality > Holidays Support	
T09XRR	Personal Management - Holiday Support	✓ Passed
Supported	Functionality > Pin Management	
T09VMN	Personal Management - Pin Management	✓ Passed
Supported	Functionality > Card Management	
T09IND	Personal Management - Card Management	✓ Passed
Supported	Functionality > Remote Device Control	
T04XSI	Output Inhibit and Uninhibit Remotely From C4	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
T08ARF	Door Lock and Unlock	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
T08LON	Door Remote Open	$\boldsymbol{\oslash}$ Not supported
	Comment: Open Command is not for door, but for output and switch output	
Device Cate	egory > ACS	
T08FDN	Door Open Permanently	$\boldsymbol{\oslash}$ Not supported
	Comment: Command doesn't exist for Open. For this use case is output	
T08ICK	Door Forced Open	✓ Passed
T08JRH	Door Open Too Long	✓ Passed
T08OCH	Request to Exit Button	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
T09CRN	Personal Management - Handling Access Granted Event	✓ Passed
T09EZJ	Personal Management - Biometric - Fingerprint	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
T09UPY	Personal Management - Antipassback Forgiveness	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
TOBBCP	Duress Alarm	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
TOBHSL	Tamper	$\boldsymbol{\oslash}$ Not supported
	Comment: not supported by the device	
TOFAFL	Unified Time Management - Time Synchronization When Changed on Device	⊘ Not supported
	Comment: not supported by the protocol, the API does not support time synch	hronization
T0FCVB	Contact Monitoring from Device	⊘ Not supported
	Comment: This is not supported by driver	-
TOFLFU	Activating Test Mode on Detector from Device	Ø Not supported
101 11 0	Comment: not supported by the device	
TOFQCA	Mains Failure	Ø Not supported
	Comment: not supported by the device	
TOFVUH	Activating Test Mode on Detector Remotely from C4	Ø Not supported
	Comment: not supported by the device	
TOFWIK	Unified Time Management - Time Synchronization on Driver Startup	Ø Not supported
	Comment: not supported by the protocol, the API does not support time synch	

T0FYDS	Unified Time Management - Periodical Synchronization Comment: not supported by the protocol, the API does not support time synch	Ø Not supported ronization		
TOFYGI	Battery Failure	$\boldsymbol{\oslash}$ Not supported		
	Comment: not supported by the device			
T2FESO	Device Audit Log Retrieval	$\boldsymbol{\oslash}$ Not supported		
	Comment: not supported by the device			
T3FIGI	Output Activation and Deactivation	✓ Passed		
T7FHSW	Missing HW Item	Ø Not supported		
	Comment: The test is not supported due to communication protocol limitations	5.		
T7FKUJ	Device Auto import	Ø Not supported		
	Comment: not supported by the protocol			
Device Category > Other				
T7FHSW	Missing HW Item	Ø Not supported		
	Comment: The test is not supported due to communication protocol limitations	5.		
T7FKUJ	Device Auto import	Ø Not supported		
	Comment: not supported by the protocol			

Appendix A

Integration Tests

T08ICK - Door Forced Open

This test verifies behavior of the driver implementation for remote controlling of doors

This test focuses on handling events and statuses during the unauthorized opening of the door in a protected system.

Test Steps

Activate door contact

Expected Results

1.Door status is set to Forcibly open

Following events are stored in audit log:

Door 'DEVICE' forced open.

Where

DEVICE represents the door name

T08JRH - Door Open Too Long

This test verifies behavior of the driver implementation for remote controlling of doors.

This test focuses on handling events and states during the held open alarm on the door.

Test Steps

Use the credential to access the access point Activate door contact Keep the contact activated longer than the predefined time

Expected Results

After successful credential authorization, the door status is set to Unblocked. Door status is set to Open when the door contact is activated. After predefined open time expiration, the door status is set to OpenTooLong.

Following events are stored in audit log:

'DEVICE' opened by 'PERSON'. Door 'DEVICE' open too long.

Where

DEVICE represents the door name PERSON represents the name of person who used authorized credential

T09CRN - Personal Management - Handling Access Granted Event

This test verifies behavior of the driver when receiving the access granted event from the device.

Test Steps

Create new person Assign the person a valid credential Grant the person access to the access point Send credentials to the device Use the credential to access the access point

Expected Results

Person got access to specific access point Access point status is set to Unblock

Following events are stored in audit log:

Access granted to 'PERSON' at 'DEVICE'

Where

PERSON represents the name of person who get access to device DEVICE represents the door name

T09IND - Personal Management - Card Management

This test verifies behavior of the driver implementation for transferring the card credentials into the device memory, allowing to define access permissions based on them.

Test Steps

Create new person Grant the person access to the access point Assign valid Card to this person Send credentials to the device Use the credential to access the access point

Expected Results

Person has correctly defined permissions in a device

Following events are stored in audit log:

```
'PERSON' cleared access data on 'DEVICE'
Access granted to 'PERSON1' at 'DEVICE1'.
```

Where

PERSON represents a name of person who executed the command PERSON1 represents a name of person who used credentials on access point DEVICE represents the device where the credentials are sent into DEVICE1 represents a name of access point

T09LQY - Personal Management - Access Time Restriction

This test verifies behavior of the driver implementation for time limited access scenarios, allowing to update the device configuration in that a way, that the access can be limited to some specific hours and/or days of the week.

Test Steps

Create new person Assign the person a valid credential Grant the person access to the access point Restrict the access permission with time restriction Send credentials to the device Check whether the restriction is applied correctly

Expected Results

The assigned time restriction is correctly applied When person has no limitation in access it gets access granted event. When person has limited access by time restriction it gets access denied event.

Following events are stored in audit log:

```
'PERSON' cleared access data on 'DEVICE'
Access granted to 'PERSON1' at 'DEVICE1'.
Access denied to 'PERSON1' at 'DEVICE1'. Reason: Active time restriction
```

Where

PERSON represents a name of person who executed the command PERSON1 represents a name of person who used credentials on access point DEVICE represents the device where the credentials are sent into DEVICE1 represents a name of access point

Notes:

Some devices might impose limits on the complexity and/or amount of available time restrictions. These limits must be enumerated in test notes and validated during this test.

T09UVU - Personal Management - Card Learning

This test verifies behavior of the driver when device provides enough information about the unknown card, that card information can be constructed from these data and new card can be created in a system.

Test Steps

Create new person Execute Learn Card feature on this person Choose correct device for card learning Slide the card on this device

Expected Results

A card of device supported type is created and assigned to the person

Following events are stored in audit log:

```
'PERSON' created Card 'CARDNAME' into 'DECK'.
'PERSON' activated 'CARDNAME' to 'PERSON1'.
Where:
```

PERSON represents a name of person who is executing the command PERSON1 represents a name of person who got card assigned to CARDNAME represents a name of card with it's card number DECK represents a name of card deck

Notes:

Some devices might have some limitations in providing information abut the unknown card Valid only on devices providing enough information about the unknown card, that the card information can be constructed from these data and new card can be created in a system

T09VMN - Personal Management - Pin Management

This test verifies behavior of the driver implementation for transferring the PIN credentials into the device memory, allowing to define access permissions based on them.

Test Steps

Create new person. Grant the person access to the access point Assign valid PIN to this person Send credentials to the device Check, whether the definitions were transferred correctly – either by reading the device memory directly or by proving operation on the device

Expected Results

Person has correctly defined permissions in a device.

Following events are stored in audit log:

```
'PERSON' cleared access data on 'DEVICE'
'AREA' was armed by 'PERSON1'.
```

Where

PERSON represents a name of person who executed the command PERSON1 represents a name of person who used credentials on access point DEVICE represents the device where the credentials are uploaded into AREA represents the name of area

Notes:

Some devices might have some limitations in PIN length or some rules to define valid PIN.

T09XRR - Personal Management - Holiday Support

This test verifies behavior of the driver implementation for manipulation with a list of holidays in the device, allowing to define the different rules for holidays than for normal working days or weekends.

Test Steps

Create new person Assign the person a valid credential Create holiday set, containing the todays date Send credentials to the device Check whether the restriction is applied correctly Modify holiday set that it doesn't contain todays date Send credentials to the device Check whether the restriction is applied correctly

Expected Results

1. The assigned time restriction is correctly applied

Following events are stored in audit log:

```
'PERSON' cleared access data on 'DEVICE'.
```

Where

PERSON represents a name of person who executed the command DEVICE represents the device where the credentials are uploaded into

Notes:

Some devices might impose limits on the complexity and/or amount of available time restrictions. These limits must be enumerated in test notes and validated during this test.

T3FIGI - Output Activation and Deactivation

This test verifies behavior of the driver implementation for output contact monitoring and controlling support.

Test Steps

Execute command "On" on output. After the output is opened, execute command "Off" on it.

Expected Results

When output is activated, its status is Open. When output is deactivated, its status is Normal.

Following events are stored in audit log:

```
'PERSON' sent command 'On' to 'DEVICE'.
'DEVICE' opened.
PERSON' sent command 'Off' to 'DEVICE'.
'DEVICE' closed.
```

Where

PERSON represents the name of person who executed the commands DEVICE represents the output name